



La Pine Fire District Mobile Food Concession (food truck/trailer/tent) Fire Safety Self-Inspection

Please take a few moments to help ensure your mobile food concession that has been placed within the La Pine Fire District (La Pine – Sunriver area) is fire safe by checking the following items:

Location, Access and Exits

1. Ensure mobile food concession is not located within twenty (20') feet of another concession, vehicles, buildings or combustibles. *Exception: If equipped with a Type 1 hood and commercial cooking suppression system the distance can be reduce to five (5') feet.*
OK Needs Correction
2. Ensure mobile food concession is not located within twenty (20') feet of a building exit egress and pathway.
OK Needs Correction
3. Ensure mobile food concession is not blocking any fire lane(s), fire hydrant and/or required fire accesses.
OK Needs Correction
4. Mobile food concession is to have a minimum of one exit door of at least 28" width and clear three (3') foot wide exit pathway leading directly out of the area without exiting though any intervening spaces, concessions stands and/or booths.
OK Needs Correction

LP Gas and Electrical Utilities

5. LPG tanks are limited to 125 gallons total and may not be installed within the interior of the mobile food concession.
OK Needs Correction
6. LPG tanks and piping are to be secured and protected from vehicle impact.
OK Needs Correction
7. Generators shall not be installed and/or operated within the interior of the mobile food concession.
OK Needs Correction
8. Electrical equipment and wiring shall be listed and labeled for the use and shall be maintained in good working condition suitable for public spaces and potentially wet environments.
OK Needs Correction
9. Electrical shore line/cords to generator and/or to power hook up shall be protected where exposed.
OK Needs Correction
10. All wiring circuits shall be Ground Fault Circuit Interrupters (GFCI) protected.
OK Needs Correction

Required Equipment

- 11. Each mobile food concession needs at least one (1) fire extinguisher, with a minimum UL rating of 2A-10BC within a 30' travel distance. **OK** **Needs Correction**
- 12. Fire extinguisher(s) to be installed in a visible and accessible location (*Suggested locations are near exits and/or service counter*) **OK** **Needs Correction**
- 13. Fire extinguisher(s) to have been serviced within the last 12 months (yearly) by a certified fire extinguisher service and has an attached tag proving such. **OK** **Needs Correction**
- 14. Mobile food concession shall have ventilation over the cooking area. **OK** **Needs Correction**
- 15. A Type 1 Hood and Commercial Cooking Suppression over the cooking area will be required if the mobile food concession produces grease laden vapor and/or has a deep frying operation and does not meet the 20' required setbacks in item #1. **OK** **Needs Correction**
- 16. If the mobile concession has a commercial hood with an extinguishing system, it must have been serviced within the last 6 months (bi-yearly) by a certified fire extinguisher service and have an attached tag proving such. **OK** **Needs Correction**
- 17. Each mobile food concession shall have a working carbon monoxide (CO) detector if there is any potential source such as LP gas use and/or a generator. **OK** **Needs Correction**

Thank you for taking the time to improve the safety of your business and mobile food concession. If you have any questions, or would like some technical assistance, please do not hesitate to call the La Pine Fire District at 541-536-2935.

Please correct all items that need attention.

Please return a completed copy of this inspection and important information below for our records for your business located in the La Pine – Sunriver area. (51590 Huntington Road, P.O. Box 10 or Fax 541-536-2627)

Emergency Contact Information:

Business _____

Street Address _____

Mailing Address _____

Manager _____ Phone _____

Owner _____ Phone _____